

Parkway Oil Co., Inc.

425 Greenfield St., Fairfield, CT 06825 • (203) 367-0083

SERVICE CONTRACT

Proper maintenance of your heating equipment results in uninterrupted convenience and comfort. Have your heating system ready to serve you efficiently when you need it.

This contract issued for domestic type oil burners only. EXCLUDED from this Service Contract are GE compressor type units, low pressure, Timkens, rotary, commercial and industrial burners.

WE GIVE 24 HOUR EMERGENCY SERVICE ON LEGITIMATE NO HEAT CALLS ONLY. (Noises and odors, etc. not considered emergency. These calls answered at owners expense after 4 p.m., weekends and holidays.)

1. Service Contract covers one (1) oil burner and one (1) heating zone controlled by standard controls.
2. This Service Contract includes one (1) cleaning per year done between May 1st and August 30th.* On steam or vapor systems, low water cut-offs and/or water feeders will be flushed and tested when oil burner is serviced. However, due to the nature of this control, responsibility for its failure and or damages, direct or indirect, resulting from such failure, will not be assumed by this company. Frequent flushing of low water cut-off by the owner is recommended to prevent possible failure.
3. This contract does not cover electrical switches in an OFF position, thermostats turned down, boilers not filled to operating level, blown fuses or empty oil tanks. (running out of oil) Service agreement does not cover labor or materials required as a result of flooded cellars, water damage, fire, running out of oil or other abnormal conditions. We reserve the right to reject any oil burner equipment from service agreement coverage. Air filters changed once per year at time of cleaning. Service may be provided by a licensed sub-contractor engaged by Parkway Oil Company, Inc.
4. This Service Contract may be terminated by either party at any time. Should this Contract be terminated, there will be no refund.
5. This Service Contract is only available to customers of PARKWAY OIL COMPANY, INC. Customer must purchase all fuel deliveries from PARKWAY OIL COMPANY, INC.
6. We will not be liable for any damage if there is not heat in unattended houses.
7. This Service Contract covers all parts listed below and labor to install them. All parts NOT COVERED by Service Contract, and LABOR to install these parts will be charged to customer.
8. Customer represents that the oil storage tank does not have an overhead or bottom feed oil supply line.

INCLUDED in this contract is repair and replacement of the following items:

Air Filters (Standard)	Belt Driven Blower Motor to 1/3 hp	Circular Couplings	Porcelains	Fuel Pump Gasket	Oil Filter Cartridge
Airstat	Burner Motor	Circulator Motor	Emergency Switch	Nozzle Line	Pressure-Trol
Aquastat	Blower Motor Pulley	Circulator Relay	Fuel Pump	Ignition Transformer	Primary Controls
Burner Couplings	Blower Belt	Elec. Wiring of Controls	Fuel Pump Strainer	Nozzle	Thermostat (standard)

The obligation to furnish replacement parts is subject to availability from our normal sources of supply. Obsolete burner parts, motors and controls not so available shall limit the obligation of this agreement. Modern equipment will be installed at list prices. This agreement is limited to power driven, oil burning equipment of a domestic type under 25 years old.

NOT INCLUDED in this contract are:

air handlers, one piece circulators - venting of radiators - draining of expression tanks - piping - duct work - smoke pipe and draft regulator - radiation - zone valves - circulators - bracket assemblies - cleaning of boiler water - humidifiers - electronic air cleaners - low water cut-offs - automatic water feeders - domestic hot water coils or any service considered to be plumbing - combustion chambers - repair to boiler and jacket on water units - repair to heat exchanger and jacket on warm air units - blower assembly - expansion tanks - radiator vent and relief valves - motorized zone valves and dampers - clock thermostats - electrical wiring - direct drive blower motors - draft inducers - oil tanks - oil lines - fittings - Blast Tubes - nozzle assembly and end cones - replacement parts after running out of oil - blower pulley, overhead or bottom feed oil lines, fire valves, tiger loop, air conditioning or combo heating/cooling parts. Outside oil tanks must be enclosed and protected from the weather. Not covered by this contract are Triple Aquastat which include but are not limited to R8182D and R8182H.

The equipment covered by this agreement is subject to inspection and approval. At our option the inspection may be waived. Any repairs required to initially put equipment in acceptable condition will be charged separately.

Customer Signature	Anniversary Date ____/____/____ to ____/____/____	Accepted By: _____ Parkway Oil Company, Inc.
Name	Address	Town